



GENERAL NOTES:

1. FOR INSTALLATION IN ROADWAYS, DRIVEWAYS, SIDEWALKS, OR PARKING AREAS PRIOR APPROVAL REQUIRED.
2. NO CONCRETE FLOOR ALLOWED IN METER PIT.
3. METER PIT SHALL BE CONSTRUCTED OF ANY COMBINATION OF CONCRETE RINGS TOTAL - 48" IN LENGTH.
4. ADJUSTMENT RINGS SHALL BE 2", 3", 4" OR 6" IN HEIGHT AND SHALL BE INSERTED BETWEEN THE DOME AND TOP RING.
5. NO CONNECTIONS OR CHANGES IN PIPE DIAMETER SHALL BE MADE FROM THE MAIN TAP TO A DISTANCE OF FIVE FEET BEYOND THE METER PIT WALL ON THE OUTLET SIDE.
6. LID SHALL SAY "WATER METER".

METER SIZE	A	B	C	D
5/8"x 3/4"	12-5/8"	7-13/16"	7-13/16"	4"
3/4"	14-1/4"	9-5/16"	8-15/16"	5"
1"	17-1/4"	11-1/16"	11-1/4"	6"

SHEET 1 OF 2



STANDARDS &
SPECIFICATIONS

REVISED:

**IRRIGATION
1" METERS
AND BELOW**

DATE:

DRAWING NO. 200-19